

Cowichan Valley Regional District
Cherry Point Estates Water System - Manganese (Mn) Results Summary
2017 to 2024

Sampling Date	UNITS	MAC	AO	Total Mn - Distribution	Sampling Location
July 23, 2024	ug/L	120	20	87.0	S1 - 1108 Paradise Cl
July 23, 2024	ug/L	120	20	93.8	S4 - Reservoir Outlet
July 16, 2024	ug/L	120	20	85.7	S1 - 1108 Paradise Cl
July 16, 2024	ug/L	120	20	131.0	S4 - Reservoir Outlet
April 2, 2024	ug/L	120	20	43.4	S1 - 1108 Paradise Cl
April 2, 2024	ug/L	120	20	64.3	S4 - Reservoir Outlet
January 9, 2024	ug/L	120	20	65.1	S4 - Reservoir Outlet
January 9, 2024	ug/L	120	20	95.4	S1 - 1108 Paradise Cl
October 16, 2023	ug/L	120	20	80.3	S4 - Reservoir Outlet
July 20, 2023	ug/L	120	20	101.0	S4 - Reservoir Outlet
July 20, 2023	ug/L	120	20	110.0	S1 - 1108 Paradise Cl
April 11, 2023	ug/L	120	20	114.0	S4 - Reservoir Outlet
January 17, 2023	ug/L	120	20	68.1	S4 - Reservoir Outlet
October 28, 2021	ug/L	120	20	44.0	S1 - 1108 Paradise Cl
June 11, 2019	ug/L	120	20	55.0	S1 - 1108 Paradise Cl
October 19, 2017	ug/L	120	20	45.3	S1 - 1108 Paradise Cl
November 15, 2022	ug/L	120	20	136.0	Well - Tap on Inlet from well in TB
December 15, 2020	ug/L	120	20	132.0	Well - Tap on Inlet from well in TB
June 14, 2018	ug/L	120	20	206.0	Well - Tap on Inlet from well in TB
October 19, 2017	ug/L	120	20	159.0	Well - Tap on Inlet from well in TB

MAC: Maximum Allowable Concentration

AO: Aesthetic Objective