

Cowichan Valley Regional District
Dogwood Ridge Water System - Manganese (Mn) Results Summary
2017 to 2025

Sampling Date	UNITS	MAC	AO	Total Mn - Distribution	Sampling Location
July 8, 2025	ug/L	120	20	55.9	S2 - tap on distribution inside TB
July 8, 2025	ug/L	120	20	37.1	S1 - 2628 Bruce Rd
April 24, 2025	ug/L	120	20	68.7	S2 - tap on distribution inside TB
April 24, 2025	ug/L	120	20	50.2	S1 - 2628 Bruce Rd
January 23, 2025	ug/L	120	20	33.3	S2 - tap on distribution inside TB
January 23, 2025	ug/L	120	20	32.3	S1 - 2628 Bruce Rd
November 27, 2024	ug/L	120	20	57.2	S1 - 2628 Bruce Rd
November 27, 2024	ug/L	120	20	50.4	S2 - tap on distribution inside TB
July 11, 2024	ug/L	120	20	45.8	S2 - Tap on Distribution inside TB
July 11, 2024	ug/L	120	20	67.8	S1 - 2628 Bruce Rd
April 18, 2024	ug/L	120	20	40.7	S1 - 2628 Bruce Rd
April 18, 2024	ug/L	120	20	79.9	S2 - Tap on Distribution inside TB
January 16, 2024	ug/L	120	20	76.5	S2 - Tap on Distribution inside TB
January 16, 2024	ug/L	120	20	71.3	S1 - 2628 Bruce Rd
October 30, 2023	ug/L	120	20	49.1	S1 - 2628 Bruce Rd
October 16, 2023	ug/L	120	20	66.3	S2 - Tap on Distribution inside TB
July 20, 2023	ug/L	120	20	60.6	S2 - Tap on Distribution inside TB
April 11, 2023	ug/L	120	20	64.6	S2 - Tap on Distribution inside TB
January 17, 2023	ug/L	120	20	64.4	S1 - 2628 Bruce Rd
January 17, 2023	ug/L	120	20	101	S2 - Tap on Distribution inside TB
March 2, 2021	ug/L	120	20	105	S1 - 2628 Bruce Rd
February 22, 2017	ug/L	120	20	38.1	S1 - 2628 Bruce Rd

MAC: Maximum Allowable Concentration

AO: Aesthetic Objective