

Cowichan Valley Regional District
Lambourn Water System - Manganese (Mn) Results Summary
2017 to 2024

Sampling Date	UNITS	MAC	AO	Total Mn - Distribution	Sampling Location
Thursday, May 16, 2024	ug/L	120	20	7.4	S2 - 4533 Lanes Rd
Tuesday, April 2, 2024	ug/L	120	20	5.6	S4 - Across from 1221 Sutherland Dr
Tuesday, April 2, 2024	ug/L	120	20	9.4	S2 - 4533 Lanes Rd
Tuesday, April 2, 2024	ug/L	120	20	10.8	S1 - Chestnut Rd (Reservoir)
Tuesday, February 27, 2024	ug/L	120	20	83.6	S2 - 4533 Lanes Rd
Tuesday, January 30, 2024	ug/L	120	20	54.8	S4 - Across from 1221 Sutherland Dr
Tuesday, January 30, 2024	ug/L	120	20	71	S2 - 4533 Lanes Rd
Tuesday, January 9, 2024	ug/L	120	20	98.1	S1 - Chestnut Rd (Reservoir)
Tuesday, January 9, 2024	ug/L	120	20	138	S2 - 4533 Lanes Rd
Thursday, October 26, 2023	ug/L	120	20	79.1	S3 - Treatment Building
Thursday, July 20, 2023	ug/L	120	20	64.8	S3 - Treatment Building
Tuesday, April 11, 2023	ug/L	120	20	82.3	S3 - Treatment Building
Wednesday, November 2, 2022	ug/L	120	20	73	S2 - 4533 Lanes Rd
Tuesday, October 25, 2022	ug/L	120	20	34.8	S4 - Across from 1221 Sutherland Dr
Tuesday, October 25, 2022	ug/L	120	20	80.5	S2 - 4533 Lanes Rd
Tuesday, October 25, 2022	ug/L	120	20	89.5	S3 - Treatment Building
Tuesday, October 25, 2022	ug/L	120	20	92.9	S1 - Chestnut Rd (Reservoir)
Tuesday, March 2, 2021	ug/L	120	20	279	S2 - 4533 Lanes Rd
Wednesday, August 1, 2018	ug/L	120	20	118	S2 - 4533 Lanes Rd
Thursday, January 11, 2018	ug/L	120	20	62.1	S3 - Treatment Building
Thursday, October 19, 2017	ug/L	120	20	25.1	S4 - Across from 1221 Sutherland Dr
Thursday, October 19, 2017	ug/L	120	20	87.6	S3 - Treatment Building
Thursday, October 19, 2017	ug/L	120	20	89.7	S3 - Treatment Building
Tuesday, September 26, 2017	ug/L	120	20	98.8	S3 - Treatment Building
Tuesday, September 26, 2017	ug/L	120	20	144	S3 - Treatment Building
Wednesday, September 20, 2017	ug/L	120	20	17.3	S4 - Across from 1221 Sutherland Dr
Wednesday, September 20, 2017	ug/L	120	20	98.3	S3 - Treatment Building
Tuesday, January 17, 2017	ug/L	120	20	74.6	S3 - Treatment Building

MAC: Maximum Allowable Concentration

AO: Aesthetic Objective