

**Cowichan Valley Regional District**  
**Kerry Village Water System - Manganese (Mn) Results Summary**  
**2017 to 2025**

Sampling Date	UNITS	MAC	AO	Total Mn - Distribution	Sampling Location
October 22, 2025	ug/L	120	20	2.9	S3 1070 Briarwood Dr
October 22, 2025	ug/L	120	20	< 1.0	S1 Water Treatment Bldg
July 8, 2025	ug/L	120	20	2.2	S3 1070 Briarwood Dr
July 8, 2025	ug/L	120	20	3.8	S1 Water Treatment Bldg
May 14, 2025	ug/L	120	20	< 1.0	S3 1070 Briarwood Dr
April 24, 2025	ug/L	120	20	1	S1 Water Treatment Bldg
April 24, 2025	ug/L	120	20	2	S3 1070 Briarwood Dr
January 23, 2025	ug/L	120	20	< 1.0	S1 Water Treatment Bldg
January 23, 2025	ug/L	120	20	< 1.0	S3 1070 Briarwood Dr
November 27, 2024	ug/L	120	20	2.4	S1 Water Treatment Bldg
July 11, 2024	ug/L	120	20	< 1.0	S1 Water Treatment Bldg
April 2, 2024	ug/L	120	20	1.7	S1 Water Treatment Bldg
January 4, 2024	ug/L	120	20	< 1.0	S1 Water Treatment Bldg
January 4, 2024	ug/L	120	20	3.0	S3 1070 Briarwood Dr
October 11, 2023	ug/L	120	20	1.7	S1 Water Treatment Bldg
October 11, 2023	ug/L	120	20	1.4	S3 1070 Briarwood Dr
July 20, 2023	ug/L	120	20	< 1.0	S1 Water Treatment Bldg
April 11, 2023	ug/L	120	20	1.3	S1 Water Treatment Bldg
January 4, 2023	ug/L	120	20	1.3	S1 Water Treatment Bldg
July 13, 2022	ug/L	120	20	9.4	S1 Water Treatment Bldg
November 8, 2021	ug/L	120	20	73	S3 1070 Briarwood Dr
June 11, 2019	ug/L	120	20	81	S3 1070 Briarwood Dr
June 11, 2018	ug/L	120	20	71	S3 1070 Briarwood Dr
October 19, 2017	ug/L	120	20	91.7	S3 1070 Briarwood Dr

MAC: Maximum Allowable Concentration

AO: Aesthetic Objective