

**Cowichan Valley Regional District**  
**Kerry Village Water System - Manganese (Mn) Results Summary**  
**2017 to 2024**

Sampling Date	UNITS	MAC	AO	Total Mn - Distribution	Sampling Location
Tuesday, April 2, 2024	ug/L	120	20	1.7	S1 - Water Treatment Building
Thursday, January 4, 2024	ug/L	120	20	<1.0	S1 - Water Treatment Building
Wednesday, October 11, 2023	ug/L	120	20	1.7	S1 - Water Treatment Building
Wednesday, October 11, 2023	ug/L	120	20	1.4	S3 - 1070 Briarwood Dr
Thursday, July 20, 2023	ug/L	120	20	<1.0	S1 - Water Treatment Building
Tuesday, April 11, 2023	ug/L	120	20	3	S3 - 1070 Briarwood Dr
Wednesday, January 4, 2023	ug/L	120	20	1.3	S1 - Water Treatment Building
Wednesday, July 13, 2022	ug/L	120	20	9.4	S1 - Water Treatment Building
Monday, November 8, 2021	ug/L	120	20	73	S3 - 1070 Briarwood Dr
Tuesday, June 11, 2019	ug/L	120	20	70.9	S3 - 1070 Briarwood Dr
Tuesday, June 11, 2019	ug/L	120	20	81	S3 - 1070 Briarwood Dr
Monday, June 11, 2018	ug/L	120	20	1.3	S1 - Water Treatment Building
Thursday, October 19, 2017	ug/L	120	20	91.7	S3 - 1070 Briarwood Dr

Note: Total Mn - Distribution values for "Well - 1080 Shaw/Mill Bay Road" indicate the post treatment values only

**MAC: Maximum Allowable Concentration**

**AO: Aesthetic Objective**