

Cowichan Valley Regional District
Kerry Village Water System - Manganese (Mn) Results Summary
2017 to 2024

Sampling Date	UNITS	MAC	AO	Total Mn - Distribution	Sampling Location
July 11, 2024	ug/L	120	20	<1.0	S1 - Water Treatment Building
April 2, 2024	ug/L	120	20	1.7	S1 - Water Treatment Building
January 4, 2024	ug/L	120	20	<1.0	S1 - Water Treatment Building
October 11, 2023	ug/L	120	20	1.7	S1 - Water Treatment Building
October 11, 2023	ug/L	120	20	1.4	S3 - 1070 Briarwood Dr
July 20, 2023	ug/L	120	20	<1.0	S1 - Water Treatment Building
April 11, 2023	ug/L	120	20	3.0	S3 - 1070 Briarwood Dr
January 4, 2023	ug/L	120	20	1.3	S1 - Water Treatment Building
July 13, 2022	ug/L	120	20	9.4	S1 - Water Treatment Building
November 8, 2021	ug/L	120	20	73.0	S3 - 1070 Briarwood Dr
June 11, 2019	ug/L	120	20	70.9	S3 - 1070 Briarwood Dr
June 11, 2019	ug/L	120	20	81.0	S3 - 1070 Briarwood Dr
June 11, 2018	ug/L	120	20	1.3	S1 - Water Treatment Building
October 19, 2017	ug/L	120	20	91.7	S3 - 1070 Briarwood Dr

Note: Total Mn - Distribution values for "Well - 1080 Shaw/Mill Bay Road" indicate the post treatment values only

MAC: Maximum Allowable Concentration

AO: Aesthetic Objective