

## KERRY PARK ARENA - Inspection Report

**Inspection Information:**

Facility Type: DWQ  
Inspection type: Routine  
Inspection date: October 26, 2015  
Follow-up Required: No

This facility was given a **low** hazard rating.

- More information on hazard ratings.

**Violations:**

No violations were found during the inspection

**Comments:** Recent bacteriological samples have been satisfactory. Annual Report for 2014 is complete and posted on-line. ERP is up to date. Chemical analysis done in 2013. Wellhead is protected, new well cap was installed. Chlorine residuals monitored and recorded twice weekly. Access to the well and reservoir are secured and locked.